

COMMISSIONERS:
 STAN VANDERWERF (CHAIR)
 CAMI BREMER (VICE-CHAIR)

HOLLY WILLIAMS
 CARRIE GEITNER
 LONGINOS GONZALEZ, JR.

FINANCIAL SERVICES DEPARTMENT
 EILEEN GONZALES, CPPO, CPPB – CONTRACTS & PROCUREMENT MANAGER

IFB NO. 21-036

DUE DATE: MARCH 23, 2021

ADDENDUM NO. 1
For
ADA ACCESSIBILITY IMPROVEMENTS AT EI PASO COUNTY FAIRGROUNDS

DATE OF ADDENDUM: MARCH 9, 2021

THE ATTACHED addendum shall become as fully a part of the above named IFB as if therein included and shall take full and complete precedence over anything contained to the contrary.

ACKNOWLEDGMENT: Each bidder shall indicate acknowledgment of receipt of this addendum by signing below and submitting this addendum (this page only) with the bid.

Each bidder shall be responsible for reading every item on the attached addendum to ascertain to what extent and in what manner it affects the work being proposed.

No attempt is made to list Addendum items in chronological order or in conformity with the Drawings to which they refer or which they affect.

| | |
|-------------------------------------|---|
| <input type="checkbox"/> | NO CHANGE TO DUE DATE |
| <input checked="" type="checkbox"/> | CHANGE DUE DATE TO: TUESDAY, MARCH 23, 2021 @ 1:00 PM (MT) (WAS THURSDAY, MARCH 18, 2021 @ 1:00 PM (MT)) |

Change Question Due Date To: Friday, March 12, 2021 @ 3:00 PM

I acknowledge receipt of this addendum which shall become a part of the submitted proposal.

| | |
|----------------------------------|--------------|
| COMPANY NAME | PHONE |
| AUTHORIZED REPRESENTATIVE | TITLE |
| SIGNATURE | DATE |



The following is hereby made a part of this solicitation:

SPECIFICATION CHANGES:

On Page 2 of General Specifications, Scope of Work, Section A. Project Description:

2. **Concrete Sidewalk Renovation** – Demolish and reconstruct approximately **840 SF** (was 500 SF) of concrete sidewalks between the pavilion and grandstands to achieve ADA accessibility standards (5% maximum grade).
3. **Concrete Sidewalks** – Install approximately **2,680 SF** (was 1,845 SF) of new 6” reinforced concrete sidewalks. One sidewalk will extend from the pavilions to Swink Arena. A second sidewalk will connect the new asphalt path to the existing playground. The third sidewalk will connect the new asphalt path to the existing sidewalk that leads to the Whitmore building.

REVISIONS TO BID FORM:

- Added 340 SF of concrete to remove on line #3.
- Added 340 SF of new 6” concrete to line #9.
- Added a line (#19) to capture the 15 LF of curb and fence work near the beer garden.

REVISIONS TO PLANS:

- On sheet C-2 added two areas for concrete removal and replacement for a total of 340 SF.
- On sheet D-2, detail 3 clarified the length of new curb and fence.

ATTACHMENTS:

1. Revised IFB Attachment 7. Bid Form
2. Revised IFB Attachment 1. Project Site Plan with Construction Details

END OF ADDENDUM NUMBER ONE.

All other terms and conditions of the original IFB shall remain unchanged and the subsequent bids received as a result of this solicitation shall be opened and evaluated in accordance with those terms and conditions.

Please sign the addendum signature page and return it with your bid. Failure to acknowledge this addendum in writing may be cause for rejection of your bid.

David Carey

David Carey, CPPB
Procurement Specialist