



El Paso County
Contracts and Procurement Division
15 East Vermijo Avenue
Colorado Springs, Colorado 80903
INVITATION FOR BID IFB 22-086
Addendum #2 – June 15, 2022

**THIS ADDENDUM SHALL BECOME A PART OF THE SOLICITATION
AND MUST BE ACKNOWLEDGED**

Invitation For Bid IFB 22-086 – ARPA Road Resurfacing Project - dated May 25, 2022

CLARIFICATIONS:

El Paso County will only accept electronic bid proposals submitted through the Rocky Mountain E-Purchasing system. A Submittal Log will be posted after the County has had an opportunity to review and verify the submittals offered to the County.

The original Offer must be received before the due date and time through electronic package through the Rocky Mountain E-Purchasing system. The Vendor is responsible for ensuring their proposal is posted by the due date and time outlined in the solicitation document.

If the submittal arrives late, it will not be included in the electronic lockbox.

ADMINISTRATION:

- The question period has expired
- We will be verifying submittals include the following:
 - Response Checklist (completed and signed by authorized representative).
 - All items on the Response Checklist.
 - Addendum(s) Acknowledged/signed (if applicable).
 - Provide evidence of vendor's financial stability, on or with the Qualification Statement.
 - Summary of vendor's background & experience, including references (3 minimum), on or with Qualification Statement.
 - List of other projects and firm's availability to complete this project in the County's noted timeframe, on or with Qualification Statement.
 - Schedule (on or with Qualification Statement).
 - Bid Form (completed and signed by authorized representative).

If a submittal is missing any of the above-mentioned documentation the submittal may be returned to the vendor as non-responsive and be deemed ineligible to participate.

RESPONSE TO QUESTIONS:

1. Project special provision 1, it states the installation of manhole rings and water valves will be paid for by the county at the contract price. There are no pay items for this. **This work is not considered part of this work and the requirement verbiage is removed from this project.**
2. There is 1.5" and 2" milling. the total form has full depth milling. Can these be spit up? **Yes, see revised bid form for itemized milling.**

3. It looks like some of the streets/roads from projects 1 and 2 are in this RFP. **Some roads did overlap. EPC has adjusted this bid package due date and will revise this bid form at least one week prior to bids being due based on actual awarded roadways in bid package IFB 22-084. The roadways that overlap and are able to be awarded in bid package IFB 22-084 would be the first to be eliminated from this bid package.**
4. Project special provisions number 7. Gravel roadway approaches to be paved 50 feet back from edge of mat. 50 feet goes way past the right of way. How far do we pave back? **50 feet; does not apply to private roadways. This would be within County ROW on the intersecting gravel roadway.**
5. Can we work in more than one area at a time? **Yes, schedule will be subject to county approval.**

Signature below indicates that applicant has read all the information provided above and agrees to comply in full. This addendum is considered as a section of the Invitation For Bid and therefore, this signed document shall become consideration and fully submitted with the original package.

PRINT OR TYPE YOUR INFORMATION

Company Name: _____	Fax: _____
Address: _____	City/State/Zip: _____
Contact Person: _____	Title: _____
Email: _____	Phone: _____
Authorized Representative's Signature: _____	Date: _____
Printed Name: _____	Title: _____
Email: _____	Phone: _____